

ANNEXURE-A

TRANSFORMER LOADING RECORD ON 3rd August, 2020 (@18:43:00)-MAX DEMAND OF THE MONTH =201.73MW (SCADA)					
SL NO	SUB-STATION			TOTAL [MW]	REMARK
1	YUREMBAM PG 1 [50MVA]	YUREMBAM PG 2 [50MVA]		21.8	SCADA
	10.9	10.9			
2	YUREMBAM STATE 1 [31.5MVA]	YUREMBAM STATE 2 [31.5MVA]	YUREMBAM STATE 3 [31.5MVA]	50.1	SCADA
	16.7	16.7	16.7		
3	KARONG 1 [20MVA]	KARONG 2 [20MVA]		13.8	SCADA
	6.9	6.9			
4	YAINGANGPOKPI 1 [20MVA]	YAINGANGPOKPI 2 [20MVA]	YAINGANGPOKPI 3 [20MVA]	8.5	SCADA
	4.3		4.2		
5	HUNDUNG 1 [20MVA]	HUNDUNG 2 [20MVA]		7	SCADA
	3.5	3.5			
6	KONGBA 2 [20MVA]	KONGBA 2 [20MVA]		18.7	S/S
	9.4	9.3			
7	THOUBAL 1 [20MVA]	THOUBAL 2 [20MVA]		15.6	S/S
	7.8	7.8			
8	KAKCHING 1 [20MVA]	KAKCHING 2 [20MVA]		9.8	SCADA
	4.9	4.9			
9	CHANDEL 1 [12.5MVA]	CHANDEL 2 [12.5MVA]		1.2	S/S
	0.6	0.6			
10	MOREH 1 [12.5MVA]	MOREH 2 [12.5MVA]		4.2	S/S
	2.2	2			
11	ELANGKANGPOKPI 1 [20MVA]	ELANGKANGPOKPI 2 [20MVA]		9.6	S/S
	4.8	4.8			
12	CCPUR 1 [20MVA]	CCPUR 2 [20MVA]		15.4	S/S
	7.7	7.7			
13	THANLON 1 [20MVA]	THANLON 2 [20MVA]		0.5	S/S
	0.3	0.2			
14	NINGTHOUKHONG 1 [20MVA]	NINGTHOUKHONG 2 [20MVA]		17.9	SCADA
	9.3	8.6			
15	RENGPANG [12.5MVA]			3.7	SCADA
	3.7				
16	JIRIBAM PG [6.3MVA]			0.1	SCADA
	0.1				
17	JIRIBAM STATE [20MVA]			2.5	SCADA
	2.5				
TOTAL =				200.4	<i>CALCULATED VALUE</i>
SEM= 200.46 MW@3rd AUGUST 20(18:45:00)					